

Receiver

From

Society
Reference
Address
Phone
Fax
E-mail

Item n° :

60191196

Model :

S4 16/29 T 400 V 4GG AMEIRA

Inverter application :

Allowed - min. 30Hz

Pump data

MEI $\geq 0,4$

P2 nominal requested :

5,5 kW

Min. fluid temperature :

0 °C

Max. fluid temperature :

40 °C

Max. Permitted amount of sand :

150 g/m3

Requested data

Flow :

Head :

Fluid :

Water

Fluid Temperature :

20 °C

Density :

998,3 kg/m³

Kinematic viscosity :

1,005 mm²/s

Vapor pressure :

2,34 kPa

Hydraulic data (duty point)

Flow :

Head :

Materials

Lower support

Precision Cast Steel AISI 304

Impeller

Technopolymer

Diffuser

Technopolymer

Screws

Stainless Steel AISI 304

Cable sheath

Stainless Steel AISI 304

Shaft with coupling

Stainless Steel AISI 420

Delivery port

Precision Cast Steel AISI 304

Motor data

Motor type :

4GG

Nominal power P2 :

5,5 kW

Rated voltage :

3~ 400 V

50 Hz

Nominal current :

14 A

Number of poles :

2



Rated speed :

2.850 1/min

Degree of protection :

IP 68

Curve tolerance according to ISO 9906



Weight :

71,1 kg

Dimensions in

mm

DNM

2" G-F

H

2.929

Ø

99

Pump connection

Suction side :

/

Discharge side :

2" G-F


/ --

Receiver

From

Society
Reference
Address
Phone
Fax
E-mail

Installation example without inverter



RECOMMENDATIONS FOR CORRECT INSTALLATION


- Keep a minimum distance of one metre from the bottom of the well.
- Install a non-return valve at least 10 metres from the delivery outlet of the pump.
- Install further non-return valves at 30-40 metre intervals.
- Ensure a minimum cooling flow around the motor during operation (for further information refer to the motor technical data sheet).
- Ensure that the dynamic level of the water in the well is at least one metre above the pump delivery

Receiver

From

Society
Reference
Address
Phone
Fax
E-mail

Installation example with inverter



- A : Power supply line
B : User
1 : Board to inverter (ADAC)
2 : Electric pump bleed / priming cap
3 : Manometer
4 : Membrane vase
5 : Gate valve
6 : Non-return valve
7 : Delivery pipework
9 : Electric pump
10 : Well
11 : Filters
12 : Pressure sensor (compulsory)
13 : Flow sensor (optional)
14 : Control panel (only for single-phase version, for capacitor housing)


RECOMMENDATIONS FOR CORRECT INSTALLATION

- Keep a minimum distance of one metre from the bottom of the well.
- Install a non-return valve at least 10 metres from the delivery outlet of the pump.
- Install further non-return valves at 30-40 metre intervals.
- Ensure a minimum cooling flow around the motor during operation (for further information refer to the motor technical data sheet).
- Ensure that the dynamic level of the water in the well is at least one metre above the pump delivery

Receiver

From

Society
Reference
Address
Phone
Fax
E-mail

S4 16/29 T 400 V 4GG AMEIRA
Curve tolerance according to ISO 9906


Suction side :

Discharge side :
2" G-F
--

Flow :

Head :

Rated speed :
2.850 1/min

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IT

OWNER_

ISSUE_DATE



DIMENSIONAL DRAWING

2020-10-26

Page 5 / 5


DAB PUMPS S.p.A.
Via Marco Polo, 14 - 35035 Mestrino (PD), Italy
Tel. +39 049 5125000 - Fax +39 049 5125950
www.dabpumps.com

Receiver

From

Society
Reference
Address
Phone
Fax
E-mail

S4 16/29 T 400 V 4GG AMEIRA



Dimensions in mm

Pump connection

1
2
3
4
5
6
7
8
9
10
11
12

DNM
H
Ø

2" G-F
2.929
99

Suction

Discharge
2" G-F
--

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IC

OWNER_

ISSUE_DATE